[7590-01-P]

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

Southern Nuclear Operating Company, Inc.,

Vogtle Electric Generating Plant, Units 3 and 4;

Shield Building Roof Changes

AGENCY: Nuclear Regulatory Commission.

ACTION: Exemption and combined license amendment; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from elements of the certification information of Tier 1 of the generic AP1000 design control document (DCD) and is issuing License Amendment Nos. 106 and 105 to Combined Licenses (COL), NPF-91 and NPF-92, respectively. The COLs were issued to Southern Nuclear Operating Company, Inc., and Georgia Power Company, Oglethorpe Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, and the City of Dalton, Georgia (collectively referred to as the licensee); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

DATES: The exemption and amendment were issued on January 11, 2018.

ADDRESSES: Please refer to Docket ID **NRC-2008-0252** when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- Federal Rulemaking Web site: Go to http://www.regulations.gov and search for Docket ID NRC-2008-0252. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; e-mail: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the FOR FURTHER INFORMATION CONTACT section of this document.
- NRC's Agencywide Documents Access and Management System

 (ADAMS): You may obtain publicly-available documents online in the ADAMS Public Documents collection at http://www.nrc.gov/reading-rm/adams.html. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated November 30, 2016, (ADAMS Accession No. ML16335A453) and revised by letters dated June 16 and October 6, 2017, (ADAMS Accession Nos. ML17167A335 and ML17279B086, respectively) designated License Amendment Request (LAR) 16-031.
- NRC's PDR: You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT: William (Billy) Gleaves, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-5848; e-mail: Bill.Gleaves@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Introduction

The NRC is granting an exemption from paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the Code of Federal Regulations (10 CFR), and issuing License Amendment Nos. 106 and 105 to COLs, NPF-91 and NPF-92, respectively, to the licensee. The exemption revises the plant-specific Tier 1 information and corresponding changes to COL Appendix C, and the amendment changes the plant-specific DCD Tier 2* and associated Tier 2 material incorporated into the VEGP Updated Final Safety Analysis Report, by revising the design details for the shield building roof, tension ring, and air inlets and removing tie rods. The exemption is required by paragraph A.4 of section VIII, "Processes for Changes and Departures," appendix D, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee proposed changes to plant-specific Tier 1 information and corresponding changes to COL Appendix C, plant-specific DCD Tier 2*, and associated Tier 2 material incorporated into the VEGP Updated Final Safety Analysis Report, by revising the design details for the shield building roof, tension ring, and air inlets and removing tie rods. The exemption met all applicable regulatory criteria set forth in 10 CFR 50.12, 10 CFR 52.7, and section VIII.A.4 of appendix D to 10 CFR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML17332A154.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VEGP Units 3 and 4 (COLs NPF-91 and NPF-92). The exemption documents for VEGP Units 3 and 4 can be found in ADAMS under Accession Nos. ML17332A152 and ML17332A153, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML17332A148 and ML17332A150, respectively. A summary of the amendment documents is provided in Section III of this document.

II. Exemption

Reproduced below is the exemption document issued to VEGP Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated November 30, 2016, as revised by letters dated June 16, and October 6, 2017, Southern Nuclear Operating Company requested from the Nuclear Regulatory Commission (NRC or Commission) an exemption to allow departures from Tier 1 information in the certified Design Control Document (DCD) incorporated by reference in 10 CFR part 52, appendix D, "Design Certification Rule for the AP1000 Design," as part of license amendment request (LAR) 16-031, "Shield Building Roof Changes."

For the reasons set forth in Section 3.1 of the NRC staff's Safety Evaluation which can be found in (ADAMS Accession No. ML17332A154) the Commission finds that:

- A. the exemption is authorized by law;
- B. the exemption presents no undue risk to public health and safety;
- C. the exemption is consistent with the common defense and security;
- D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;
- E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and
- F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.
- 2. Accordingly, the licensee is granted an exemption from the certified DCD Tier 1 information, allowing changes to the plant-specific DCD Tier 1 with corresponding changes to Appendix C of the Facility Combined License as described in the request dated November 30, 2016, as revised by letters dated June 16, and October 6, 2017. This exemption is related to, and necessary for, the granting of License Amendment No. 106, which is being issued concurrently with this exemption.
- 3. As explained in Section 5.0 of the NRC staff's Safety Evaluation (ADAMS Accession No. ML17332A154), this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

III. License Amendment Request

By letter dated November 30, 2016, (ADAMS Accession No. ML16335A453) and revised by letters dated June 16 and October 6, 2017, (ADAMS Accession Nos. ML17167A335 and ML17279B086, respectively), the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COLs NPF-91 and NPF-92. The proposed amendment is described in Section I of this *Federal Register* notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or COL, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the *Federal Register* on March 8, 2017 (82 FR 13019). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that the licensee requested on November 30, 2016, as revised by letters dated June 16, and October 6, 2017.

The exemption and amendment were issued to the licensee on January 11, 2018, as part of a combined package (ADAMS Accession No. ML17332A146).

Dated at Rockville, Maryland, this 2nd day of February, 2018.

For the Nuclear Regulatory Commission.

Jennifer L. Dixon-Herrity, Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.

[FR Doc. 2018-02472 Filed: 2/6/2018 8:45 am; Publication Date: 2/7/2018]